

PERFORMANCE

COMMISSIONING AGENCY

ISSUE LOG

PROJECT: SAMPLE PROJECT
 LOCATION: CITYSVILLE, ST
 STAFF: SIR ELTON JOHN

PROJECT NUMBER: 1234567
 DATE CREATED: 12/25/0001

ITEM NUMBER	ISSUE	DATE	CORRESPONDING CONTRACTOR	COMMENTS	ISSUE RESOLVED?	INITIALS
1	AHU-4 MIXED AND OUTSIDE AIR OPEN INDEPENDENTLY FROM ONE ANOTHER, MIXED AIR DAMPER STAYS OPEN DURING ECONOMIZING MODE	12/25	J&L MECHANICAL		<input checked="" type="checkbox"/>	
2	LIGHTING SWITCH IN ROOM 204B VACANCY SENSOR UNRESPONSIVE TO MOVEMENT	1/23	JTW ELECTRIC		<input type="checkbox"/>	
					<input type="checkbox"/>	
					<input type="checkbox"/>	
					<input type="checkbox"/>	
					<input type="checkbox"/>	
					<input type="checkbox"/>	
					<input type="checkbox"/>	
					<input type="checkbox"/>	



109 WIND HAVEN DRIVE, SUITE 201
 NICHOLASVILLE, KY 40356
 WWW.PERFCX.COM
 (859) 277-0191

